




# Sherman Central School

127 Park Street • P.O. Box 950 • Sherman, NY 14781-0950  
phone (716) 761-6121 • fax (716) 761-6119  
[www.shermancsd.org](http://www.shermancsd.org)



February 28, 2023

Dear School Community/Staff/Students:

It is a priority of every school district to maintain a safe and healthy learning environment for its students, and clean water is no exception. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead and restricted the lead content of faucets, pipes, and other plumbing materials. Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers, and lakes. New laws that went into effect in 2014 reduced the amount of lead that plumbing fixtures can contain from 8% to 1%. Brass faucets, fittings and valves – including those advertised as “lead free” – may still contribute lead to drinking water.

The Sherman Central School District is in compliance with New York State Public Health Laws requiring all schools and Boards of Cooperative Educational Services (BOCES) to test potable water outlets for lead contamination, to remediate contamination where found, and to notify parents of children and the public of test results. Levels of lead at any water outlet above 5 parts per billion (ppb) require action to remediate this issue.

As required, the Sherman Central School District tested all water sources in every building for lead on February 11, 2023. As provided to us under specific protocols, first draw water samples were taken after letting the water remain unmoving in the pipes over a period of 8 to 18 hours. The results of this testing were received on February 22, 2023 and of the 81 water samples tested, only 14 showed lead levels above the 5 ppb mark.

Listed below are the areas that exceeded the threshold of 5 ppb:

- K-1, Kitchen Hand Wash Sink, 7.83 ppb
- K-2, Dishwasher Room, 6.71 ppb
- K-3, Dishwasher Room Hand Wash Sink, 11.7 ppb
- K-5, Kitchen Prep Sink, 8.70 ppb
- K-8, Kitchen Dishwashing Sink, 5.45 ppb
- K-9, Kitchen Dish Washing Sink, 21.5 ppb
- K-10, Kitchen Dishwashing Sink, 28.0 ppb
- 3-18, Rm 172 Sink, 8.57 ppb
- 3-22, Rm 173 Sink, 6.51 ppb
- 3-23, Rm 173 Sink, 7.53 ppb
- 3-24, Rm 173 Sink, 6.50 ppb
- 3-36, Rm 158 Sink, 5.24 ppb
- 5-16, Rm 265 Sink, 5.48 ppb
- 5-17, Rm 263 Sink, 7.33 ppb

While we will be taking measures to resolve these sources, we are pleased to report that student drinking fountains and areas where water is used in food preparation are all at acceptable levels. The Sherman Central

---

**Mrs. Carrie Yohe** • Superintendent  
**Mrs. Nicole M. Marino** • Principal  
**Mrs. Ann M. Morrison** • Director of Pupil Services &  
Data/Grant Coordinator

**Board of Education**  
**Mr. Brian Bates** • President  
**Mrs. Emily Reynolds** • Vice President  
**Mrs. Teresa Guzman**  
**Ms. Kristin Irwin**  
**Mr. Timothy Sears**

**Mrs. Kimberly Oehlbeck** • School Business Administrator  
**Mr. Luke Waygood** • District Clerk



# Sherman Central School

127 Park Street • P.O. Box 950 • Sherman, NY 14781-0950  
phone (716) 761-6121 • fax (716) 761-6119  
[www.shermancsd.org](http://www.shermancsd.org)




District is taking a number of steps to correct the problem. We have shut off the water supply to those fixtures used for drinking or cooking. Any water sources used for other purposes such as handwashing and general cleaning have been clearly labeled with warning signs not to be used for drinking or cooking. The next step is to develop a remediation plan that will be approved and guided by the experts in the field of water remediation.

The timetable for remediation of each of the identified sources will depend on the availability of parts, installation, and the process for retesting. It is important to note that none of the sources will be put back into service and available for drinking or cooking until the sources are fully mitigated and meet New York State Department of Health Standards.

A copy of our water testing results are available at the Director of Facilities office, which is open Monday through Friday from 8:00 am to 4:00 pm. Results are also posted on the District website at [www.shermancsd.org](http://www.shermancsd.org).

For more information about water quality and sampling for lead contact the Erie County Department of Health at 961-6800 or the Chautauque County Department of Health and Human Services at 753-4000.

Sincerely,

  
Carrie Yohe  
Superintendent

---

Mrs. Carrie Yohe • Superintendent  
Mrs. Nicole M. Marino • Principal  
Mrs. Ann M. Morrison • Director of Pupil Services &  
Data/Grant Coordinator

Board of Education  
Mr. Brian Bates • President  
Mrs. Emily Reynolds • Vice President  
Mrs. Teresa Guzman  
Ms. Kristin Irwin  
Mr. Timothy Sears

Mrs. Kimberly Oehlbeck • School Business Administrator  
Mr. Luke Waygood • District Clerk



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

3022166

Sherman Central School

Project Name: Analytical Services

Jared Oehlbeck  
127 Park ST  
Sherman, NY 14781

Project / PO Number: N/A  
Received: 02/13/2023  
Reported: 02/22/2023

Analytical Testing Parameters

Client Sample ID:	Gr-2	Collected By:	Jared Oehlbeck
Sample Matrix:	Drinking Water	Collection Date:	02/11/2023 7:17
Lab Sample ID:	3022166-01		

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	1.32	15.0	0.400	ug/L			02/21/23 1125	SEV

Client Sample ID:	Gr-3A	Collected By:	Jared Oehlbeck
Sample Matrix:	Drinking Water	Collection Date:	02/11/2023 7:18
Lab Sample ID:	3022166-02		

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	15.0	0.400	ug/L		02/21/23 1132	02/21/23 1132	SEV

Client Sample ID:	Gr-3B	Collected By:	Jared Oehlbeck
Sample Matrix:	Drinking Water	Collection Date:	02/11/2023 7:18
Lab Sample ID:	3022166-03		

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	15.0	0.400	ug/L		02/21/23 1133	02/21/23 1133	SEV

Client Sample ID:	Gr-4	Collected By:	Jared Oehlbeck
Sample Matrix:	Drinking Water	Collection Date:	02/11/2023 7:20
Lab Sample ID:	3022166-04		

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	2.72	15.0	0.400	ug/L		02/21/23 1135	02/21/23 1135	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

3022166

Client Sample ID: Gr-8	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:09
Lab Sample ID: 3022166-05	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	15.0	0.400	ug/L		02/21/23 1137	02/21/23 1137	SEV

Client Sample ID: Gr-9	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:14
Lab Sample ID: 3022166-06	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	2.37	15.0	0.400	ug/L		02/21/23 1139	02/21/23 1139	SEV

Client Sample ID: Gr-10	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:15
Lab Sample ID: 3022166-07	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	1.96	15.0	0.400	ug/L		02/21/23 1141	02/21/23 1141	SEV

Client Sample ID: Gr-11A	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:12
Lab Sample ID: 3022166-08	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	15.0	0.400	ug/L		02/21/23 1142	02/21/23 1142	SEV

Client Sample ID: Gr-11B	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:14
Lab Sample ID: 3022166-09	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	15.0	0.400	ug/L		02/21/23 1144	02/21/23 1144	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

3022166

<b>Client Sample ID:</b> Gr-13									
<b>Sample Matrix:</b> Drinking Water						<b>Collected By:</b> Jared Oehlbeck			
<b>Lab Sample ID:</b> 3022166-10						<b>Collection Date:</b> 02/11/2023 7:11			

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	15.0	0.400	ug/L		02/21/23 1146	02/21/23 1146	SEV

<b>Client Sample ID:</b> Gr-14									
<b>Sample Matrix:</b> Drinking Water						<b>Collected By:</b> Jared Oehlbeck			
<b>Lab Sample ID:</b> 3022166-11						<b>Collection Date:</b> 02/11/2023 7:10			

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	15.0	0.400	ug/L		02/21/23 1153	02/21/23 1153	SEV

<b>Client Sample ID:</b> K-1									
<b>Sample Matrix:</b> Drinking Water						<b>Collected By:</b> Jared Oehlbeck			
<b>Lab Sample ID:</b> 3022166-12						<b>Collection Date:</b> 02/11/2023 7:21			

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	7.83	15.0	0.400	ug/L		02/21/23 1200	02/21/23 1200	SEV

<b>Client Sample ID:</b> K-2									
<b>Sample Matrix:</b> Drinking Water						<b>Collected By:</b> Jared Oehlbeck			
<b>Lab Sample ID:</b> 3022166-13						<b>Collection Date:</b> 02/11/2023 7:22			

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	6.71	15.0	0.400	ug/L		02/21/23 1202	02/21/23 1202	SEV

<b>Client Sample ID:</b> K-3									
<b>Sample Matrix:</b> Drinking Water						<b>Collected By:</b> Jared Oehlbeck			
<b>Lab Sample ID:</b> 3022166-14						<b>Collection Date:</b> 02/11/2023 7:23			

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	11.7	15.0	0.400	ug/L		02/21/23 1204	02/21/23 1204	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

3022166

Client Sample ID: K-4	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:24
Lab Sample ID: 3022166-15	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	2.05	15.0	0.400	ug/L		02/21/23 1206	02/21/23 1206	SEV

Client Sample ID: K-5	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:24
Lab Sample ID: 3022166-16	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	8.70	15.0	0.400	ug/L		02/21/23 1207	02/21/23 1207	SEV

Client Sample ID: K-6	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:25
Lab Sample ID: 3022166-17	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	1.28	15.0	0.400	ug/L		02/21/23 1209	02/21/23 1209	SEV

Client Sample ID: K-7	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:25
Lab Sample ID: 3022166-18	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	2.61	15.0	0.400	ug/L		02/21/23 1211	02/21/23 1211	SEV

Client Sample ID: K-8	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:26
Lab Sample ID: 3022166-19	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	5.45	15.0	0.400	ug/L		02/21/23 1213	02/21/23 1213	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

3022166

<b>Client Sample ID:</b> K-9	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Jared Oehlbeck
<b>Lab Sample ID:</b> 3022166-20		<b>Collection Date:</b> 02/11/2023 7:26

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	21.5	15.0	0.400	ug/L		02/21/23 1214	02/21/23 1214	SEV

<b>Client Sample ID:</b> K-10	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Jared Oehlbeck
<b>Lab Sample ID:</b> 3022166-21		<b>Collection Date:</b> 02/11/2023 7:27

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	28.0	15.0	0.800	ug/L		02/20/23 1000	02/21/23 1630	SEV

<b>Client Sample ID:</b> K-11	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Jared Oehlbeck
<b>Lab Sample ID:</b> 3022166-22		<b>Collection Date:</b> 02/11/2023 7:28

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	2.98	15.0	0.400	ug/L		02/21/23 1227	02/21/23 1227	SEV

<b>Client Sample ID:</b> 2-1	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Jared Oehlbeck
<b>Lab Sample ID:</b> 3022166-23		<b>Collection Date:</b> 02/11/2023 7:31

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	15.0	0.400	ug/L		02/21/23 1234	02/21/23 1234	SEV

<b>Client Sample ID:</b> 2-2	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Jared Oehlbeck
<b>Lab Sample ID:</b> 3022166-24		<b>Collection Date:</b> 02/11/2023 7:31

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	15.0	0.400	ug/L		02/21/23 1236	02/21/23 1236	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

3022166

Client Sample ID: 2-3	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:33
Lab Sample ID: 3022166-25	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.713	15.0	0.400	ug/L		02/21/23 1238	02/21/23 1238	SEV

Client Sample ID: 2-4	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:33
Lab Sample ID: 3022166-26	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.682	15.0	0.400	ug/L		02/21/23 1240	02/21/23 1240	SEV

Client Sample ID: 3-1	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:35
Lab Sample ID: 3022166-27	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.454	15.0	0.400	ug/L		02/21/23 1241	02/21/23 1241	SEV

Client Sample ID: 3-2	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:35
Lab Sample ID: 3022166-28	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.757	15.0	0.400	ug/L		02/21/23 1243	02/21/23 1243	SEV

Client Sample ID: 3-3	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:36
Lab Sample ID: 3022166-29	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.481	15.0	0.400	ug/L		02/21/23 1245	02/21/23 1245	SEV





Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

3022166

Client Sample ID: 3-6	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:37
Lab Sample ID: 3022166-30	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	15.0	0.400	ug/L		02/21/23 1247	02/21/23 1247	SEV

Client Sample ID: 3-7	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:38
Lab Sample ID: 3022166-31	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.655	15.0	0.400	ug/L		02/21/23 1248	02/21/23 1248	SEV

Client Sample ID: 3-8	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:39
Lab Sample ID: 3022166-32	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	1.06	15.0	0.400	ug/L		02/21/23 1256	02/21/23 1256	SEV

Client Sample ID: 3-10	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:40
Lab Sample ID: 3022166-33	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	1.16	15.0	0.400	ug/L		02/21/23 1303	02/21/23 1303	SEV

Client Sample ID: 3-12	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:40
Lab Sample ID: 3022166-34	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	1.68	15.0	0.400	ug/L		02/21/23 1305	02/21/23 1305	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

3022166

Client Sample ID: 3-13	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:42
Lab Sample ID: 3022166-35	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	2.23	15.0	0.400	ug/L		02/21/23 1306	02/21/23 1306	SEV

Client Sample ID: 3-14	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:42
Lab Sample ID: 3022166-36	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	1.64	15.0	0.400	ug/L		02/21/23 1308	02/21/23 1308	SEV

Client Sample ID: 3-15	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:42
Lab Sample ID: 3022166-37	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	2.04	15.0	0.400	ug/L		02/21/23 1310	02/21/23 1310	SEV

Client Sample ID: 3-16	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:43
Lab Sample ID: 3022166-38	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	3.84	15.0	0.400	ug/L		02/21/23 1312	02/21/23 1312	SEV

Client Sample ID: 3-17	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:44
Lab Sample ID: 3022166-39	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	2.51	15.0	0.400	ug/L		02/21/23 1314	02/21/23 1314	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

3022166

Client Sample ID: 3-18	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:44
Lab Sample ID: 3022166-40	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	8.57	15.0	0.400	ug/L		02/21/23 1315	02/21/23 1315	SEV

Client Sample ID: 3-22	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:44
Lab Sample ID: 3022166-41	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	6.51	15.0	0.400	ug/L		02/21/23 1317	02/21/23 1317	SEV

Client Sample ID: 3-23	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:44
Lab Sample ID: 3022166-42	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	7.53	15.0	0.400	ug/L		02/21/23 1348	02/21/23 1348	SEV

Client Sample ID: 3-24	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:45
Lab Sample ID: 3022166-43	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	6.50	15.0	0.400	ug/L		02/21/23 1356	02/21/23 1356	SEV

Client Sample ID: 3-28	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:46
Lab Sample ID: 3022166-44	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	15.0	0.400	ug/L		02/21/23 1357	02/21/23 1357	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

3022166

Client Sample ID: 3-29	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:47
Lab Sample ID: 3022166-45	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	15.0	0.400	ug/L		02/21/23 1359	02/21/23 1359	SEV

Client Sample ID: 3-33	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:52
Lab Sample ID: 3022166-46	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	2.18	15.0	0.400	ug/L		02/21/23 1401	02/21/23 1401	SEV

Client Sample ID: 3-34	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:52
Lab Sample ID: 3022166-47	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.653	15.0	0.400	ug/L		02/21/23 1403	02/21/23 1403	SEV

Client Sample ID: 3-35	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:53
Lab Sample ID: 3022166-48	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.759	15.0	0.400	ug/L		02/21/23 1404	02/21/23 1404	SEV

Client Sample ID: 3-36	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:54
Lab Sample ID: 3022166-49	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	5.24	15.0	0.400	ug/L		02/21/23 1406	02/21/23 1406	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

3022166

Client Sample ID: 3-37	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:54
Lab Sample ID: 3022166-50	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	2.13	15.0	0.400	ug/L		02/21/23 1408	02/21/23 1408	SEV

Client Sample ID: 3-38	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:55
Lab Sample ID: 3022166-51	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	2.83	15.0	0.400	ug/L		02/21/23 1410	02/21/23 1410	SEV

Client Sample ID: 3-39	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:55
Lab Sample ID: 3022166-52	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	2.25	15.0	0.400	ug/L		02/21/23 1417	02/21/23 1417	SEV

Client Sample ID: 3-45	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:57
Lab Sample ID: 3022166-53	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	15.0	0.400	ug/L		02/21/23 1424	02/21/23 1424	SEV

Client Sample ID: 3-46	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 7:57
Lab Sample ID: 3022166-54	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	15.0	0.400	ug/L		02/21/23 1426	02/21/23 1426	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

3022166

Client Sample ID: 4-4	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 8:00
Lab Sample ID: 3022166-55	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	1.40	15.0	0.400	ug/L		02/21/23 1428	02/21/23 1428	SEV

Client Sample ID: 4-5	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 8:00
Lab Sample ID: 3022166-56	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	3.95	15.0	0.400	ug/L		02/21/23 1430	02/21/23 1430	SEV

Client Sample ID: 4-6	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 8:00
Lab Sample ID: 3022166-57	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	3.54	15.0	0.400	ug/L		02/21/23 1431	02/21/23 1431	SEV

Client Sample ID: 4-7	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 8:01
Lab Sample ID: 3022166-58	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	15.0	0.400	ug/L		02/21/23 1433	02/21/23 1433	SEV

Client Sample ID: 4-8	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 8:01
Lab Sample ID: 3022166-59	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	15.0	0.400	ug/L		02/21/23 1435	02/21/23 1435	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

3022166

Client Sample ID: 5-1	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 8:05
Lab Sample ID: 3022166-60	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	15.0	0.400	ug/L		02/21/23 1437	02/21/23 1437	SEV

Client Sample ID: 5-2	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 8:06
Lab Sample ID: 3022166-61	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	15.0	0.400	ug/L		02/21/23 1438	02/21/23 1438	SEV

Client Sample ID: 5-10	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 8:06
Lab Sample ID: 3022166-62	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.807	15.0	0.400	ug/L		02/21/23 1451	02/21/23 1451	SEV

Client Sample ID: 5-11	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 8:06
Lab Sample ID: 3022166-63	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	1.56	15.0	0.400	ug/L		02/21/23 1458	02/21/23 1458	SEV

Client Sample ID: 5-12	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 8:07
Lab Sample ID: 3022166-64	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.491	15.0	0.400	ug/L		02/21/23 1500	02/21/23 1500	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

3022166

Client Sample ID: 5-13	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 8:07
Lab Sample ID: 3022166-65	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	2.38	15.0	0.400	ug/L		02/21/23 1502	02/21/23 1502	SEV

Client Sample ID: 5-14	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 8:07
Lab Sample ID: 3022166-66	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	15.0	0.400	ug/L		02/21/23 1504	02/21/23 1504	SEV

Client Sample ID: 5-15	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 8:08
Lab Sample ID: 3022166-67	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	15.0	0.400	ug/L		02/21/23 1505	02/21/23 1505	SEV

Client Sample ID: 5-16	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 8:09
Lab Sample ID: 3022166-68	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	5.48	15.0	0.400	ug/L		02/21/23 1507	02/21/23 1507	SEV

Client Sample ID: 5-17	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 8:09
Lab Sample ID: 3022166-69	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	7.33	15.0	0.400	ug/L		02/21/23 1509	02/21/23 1509	SEV





Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

3022166

Client Sample ID: 6-4	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 8:11
Lab Sample ID: 3022166-70	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	15.0	0.400	ug/L		02/21/23 1511	02/21/23 1511	SEV

Client Sample ID: 6-5	Collected By: Jared Oehlbeck
Sample Matrix: Drinking Water	Collection Date: 02/11/2023 8:11
Lab Sample ID: 3022166-71	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.400	15.0	0.400	ug/L		02/21/23 1512	02/21/23 1512	SEV

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- RL: Reporting Limit
- ug/L: Micrograms per Liter

Project Requested Certification(s)

Microbac Laboratories Inc., Pittsburgh Division  
10121

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.

Reviewed and Approved By:

Carolyn Vollentine  
Service Center Manager  
Reported: 02/22/2023 13:42

Microbac Laboratories, Inc.



CHAIN OF CUSTODY RECORD

MICROBAC 1962 Wager Rd., Erie, PA 16509 | 814.825.8533 f

Number Instructions on back

Sherman Central School  
PM: Carolyn Volentine

Lab Report Address Sherman Central School  
Client Name Sherman Central School

TO BE COMPLETED BY MICROBAC  
Temperature Upon Receipt (°C) 74.42  
Therm ID

business days  
[ ] RUSH\* (notify lab)

Holding Time 16.40

Address: 127 Park St  
City, State, Zip: Sherman, NY 14781

Invoice # 3022166  
Client Nam Sherman Central School

Samples Received on Ice? Yes No N/A

Contact: Jared Oehlbeck  
Telephone No.: 716-761-4807

Address: P.O. Box 950  
City, State, Zip: Sherman, NY 14781

Custody Seals Intact? Yes No N/A

Report Type  
[X] Results Only [ ] Level 1 [ ] Level 3 [ ] Level 4 [ ] EDD

Contact: Jared Oehlbeck  
Telephone No.: 716-761-4807

Compliance Monitoring? [X] Yes [ ] No  
( ) Agency/Program

Send Invoice via: [X] Mail [ ] Fax [ ] e-mail (address)

Send Invoice via: [X] Mail [ ] Fax [ ] e-mail (address)

PO No.: 716-761-4807

Location: Sherman CSD

Location: Sherman CSD

Sampler Phone No.: 716-761-4807

Sampler Signature: Jared Oehlbeck

Sampler Signature: Jared Oehlbeck

\* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)  
\*\* Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved  
REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types	Lead	Additional Notes
Gr-2		2/11/2023	7:17	1	DW	G	None	X	
Gr-3A		2/11/2023	7:18	1	DW	G	None	X	
Gr-3B		2/11/2023	7:18	1	DW	G	None	X	
Gr-4		2/11/2023	7:20	1	DW	G	None	X	
Gr-8		2/11/2023	7:09	1	DW	G	None	X	
Gr-9		2/11/2023	7:14	1	DW	G	None	X	
Gr-10		2/11/2023	7:15	1	DW	G	None	X	
Gr-11A		2/11/2023	7:12	1	DW	G	None	X	
Gr-11B		2/11/2023	7:14	1	DW	G	None	X	
Gr-13		2/11/2023	7:11	1	DW	G	None	X	

HNO3 Preserved  
HNO3: A204944  
Date: 2-14-23  
Time: 8:30  
Initials: SEV

Possible Hazard Identification [ ] Hazardous [ ] Non-Hazardous [ ] Radioactive [X] Dispose as appropriate [ ] Return [ ] Archive

18.4°C 2/13  
CK Trg N/A ice

Relinquished By (signature) [Signature]  
Relinquished By (signature) [Signature]  
Relinquished By (signature) [Signature]

Received By (signature) [Signature]  
Received By (signature) [Signature]  
Received By (signature) [Signature]

Date/Time 2-13-23 9:40  
Date/Time 2-13-23 11:00  
Date/Time 2-13-23 13:15  
Date/Time 2-13-23 13:25



CHAIN OF CUSTODY RECORD

Number \_\_\_\_\_  
Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C) 14.2  
Therm ID \_\_\_\_\_

Holding Time 16.4

Samples Received on Ice? Yes No (N/A)

Custody Seals Intact? Yes No (N/A)

business days) \_\_\_\_\_  
[ ] RUSH\* (notify lab)

(needed by) \_\_\_\_\_  
Report Type \_\_\_\_\_

[X] Results Only [ ] Level 1 [ ] Level 2 [ ] Level 3 [ ] Level 4 [ ] EDD  
[X] Mail [ ] Fax [ ] e-mail (address)

Compliance Monitoring? [X] Yes [ ] No  
( ) Agency/Program

Sampler Phone No.: 716-761-4807

Sherman Central School  
PM: Carolyn Vollenhine  
Sherman Central School

Invoice Ad

Client Name: Sherman Central School

Address: 127 Park St

City, State, Zip: Sherman, NY 14781

Contact: Jared Oehlbeck

Telephone No.: 716-761-4807

Send Report via: [X] Mail [ ] Fax [ ] e-mail (address)

Project: Lead Samples Location: Sherman CSD

Sampled by (PRINT): Jared Oehlbeck  
Sampler Signature: \_\_\_\_\_

\* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)  
\*\* Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved  
REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Type	Lead	Additional Notes
	Gr-14	2/11/2023	7:10	1	DW	G	None	X	
	K-1	2/11/2023	7:21	1	DW	G	None	X	
	K-2	2/11/2023	7:22	1	DW	G	None	X	
	K-3	2/11/2023	7:23	1	DW	G	None	X	
	K-4	2/11/2023	7:24	1	DW	G	None	X	
	K-5	2/11/2023	7:24	1	DW	G	None	X	
	K-6	2/11/2023	7:25	1	DW	G	None	X	
	K-7	2/11/2023	7:25	1	DW	G	None	X	
	K-8	2/11/2023	7:26	1	DW	G	None	X	
	K-9	2/11/2023	7:26	1	DW	G	None	X	

Possible Hazard Identification: [ ] Hazardous [ ] Non-Hazardous [ ] Radioactive [X] Dispose as appropriate [ ] Return [ ] Archive

18.4°C 2/13  
CK Matrix 703

Relinquished By (signature) [Signature]

Date/Time 2-13-23 9:40

Received By (signature) [Signature]

Date/Time 2-13-23 9:40

Relinquished By (signature) [Signature]

Date/Time 2-13-23 11:00

Received By (signature) [Signature]

Date/Time 2-13-23 11:00

Relinquished By (signature) [Signature]

Date/Time 2-13-23 13:15

Received By (signature) [Signature]

Date/Time 2-13-23 13:25

CHAIN OF CUSTODY RECORD

Number Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C) Therm ID

Holding Time

Samples Received on Ice? Yes No

Custody Seals Intact? Yes No

[X] Results Only [ ] Level 1 [ ] Level 2 [ ] Level 3 [ ] Level 4 [ ] EDD

[X] Mail [ ] Fax [ ] e-mail (address)

Compliance Monitoring? [X] Yes [ ] No

( ) Agency/Program

Sampler Phone No.:

716-761-4807

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis

Requested Analysis



3 0 2 2 1 6 6

Sherman Central School

PM: Carolyn Vollentine

Sherman Central School

P.O. Box 950

Sherman, NY 14781

Jared Oehlbeck

716-761-4807

Send Invoice via:

[X] Mail [ ] Fax [ ] e-mail (address)

Sherman CSD

PO No.:

716-761-4807

Sampler Signature:

Jared Oehlbeck

Date Collected

Time Collected

No. of Containers

Matrix

Grab / Comp

Preservative Types

Lead

Sample Disposition

[X] Dispose as appropriate [ ] Return [ ] Archive

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

MICROBAC 1962 Wager Rd., Erie, PA 16509 | 814.825.853

Lab Report Address Invoice

Sherman Central School Client Name:

127 Park St Address:

Sherman, NY 14781 City, State, Zip:

Jared Oehlbeck Contact:

716-761-4807 Telephone No.:

[X] Mail [ ] Fax [ ] e-mail (address) Send Report via:

Sherman CSD Location:

PO No.:

Jared Oehlbeck Sampler Signature:

7:27 Time Collected

7:28 Time Collected

7:31 Time Collected

7:31 Time Collected

7:33 Time Collected

7:33 Time Collected

7:35 Time Collected

7:35 Time Collected

7:36 Time Collected

7:37 Time Collected

Client Sample ID

K-10

K-11

2-1

2-2

2-3

2-4

3-1

3-2

3-3

3-6

1 DW G

1 DW G

1 DW G

1 DW G

1 DW G

1 DW G

1 DW G

1 DW G

1 DW G

1 DW G

1 DW G

None

None

None

Possible Hazard Identification

[ ] Hazardous [ ] Non-Hazardous

Comments

18.4°C TBG

MAIAC CK 2/13

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time

Received By (signature)

Date/Time



CHAIN OF CUSTODY RECORD

Number TO BE COMPLETED BY MICROBAC  
Instructions on back

Temperature Upon Receipt (°C) Therm ID

Holding Time 16.4°C

Samples Received on Ice? Yes No **N/A**

Custody Seals Intact? Yes No **N/A**

[X] Results Only [ ] Level 1 [ ] Level 2 [ ] Level 3 [ ] Level 4 [ ] EDD

[X] Mail [ ] Fax [ ] e-mail (address)

Compliance Monitoring? [X] Yes [ ] No  
( ) Agency/Program

Sampler Phone No.: 716-761-4807

Sherman Central School  
PM: Carolyn Volentine

Time

5 to 7 business days

[ ] KUSH\* (notify lab)

P.O. Box 950

Sherman, NY 14781

Jared Oehlbeck

716-761-4807

Send Invoice via:

PO No.:

Sherman CSD

Sampler Signature: Jared Oehlbeck

\* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

\*\* Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methylanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Type	Lead	Additional Notes
3-7		2/11/2023	7:38	1	DW	G	None	X	
3-8		2/11/2023	7:39	1	DW	G	None	X	
3-10		2/11/2023	7:40	1	DW	G	None	X	
3-12		2/11/2023	7:40	1	DW	G	None	X	
3-13		2/11/2023	7:42	1	DW	G	None	X	
3-14		2/11/2023	7:42	1	DW	G	None	X	
3-15		2/11/2023	7:42	1	DW	G	None	X	
3-16		2/11/2023	7:43	1	DW	G	None	X	
3-17		2/11/2023	7:44	1	DW	G	None	X	
3-18		2/11/2023	7:44	1	DW	G	None	X	

Possible Hazard Identification [ ] Hazardous [ ] Non-Hazardous [ ] Radioactive [X] Dispose as appropriate [ ] Return [ ] Archive

Relinquished By (signature) *Jared Oehlbeck* Date/Time 2-13-23 9:40  
 Relinquished By (signature) *Jared Oehlbeck* Date/Time 2-13-23 11:00  
 Relinquished By (signature) *Jared Oehlbeck* Date/Time 2-13-23 13:15  
 Received By (signature) *Carly Vellut* Date/Time 2-13-23 9:40  
 Received By (signature) *Carly Vellut* Date/Time 2-13-23 11:00  
 Received By (signature) *Carly Vellut* Date/Time 2-13-23 13:25

18.4°C Top  
NA Ice OK 2/15



CHAIN OF CUSTODY RECORD

MICROBAC 1962 Wager Rd., Erie, PA 16509 | 814-825-8

Page 20 of 23

Lab Report Address: Sherman Central School  
 Client: PM: Carolyn Volentine  
 Address: 127 Park St P.O. Box 950  
 City, State, Zip: Sherman, NY 14781  
 Contact: Jared Oehlbeck  
 Telephone No.: 716-761-4807  
 Send Report via: [X] Mail [ ] Fax [ ] e-mail (address)  
 Project: Lead Samples Location: Sherman CSD  
 Sampled by (PRINT): Jared Oehlbeck  
 Sampler Signature: [Signature]  
 Telephone No.: 716-761-4807  
 PO No.:  
 Location: Sherman CSD  
 Sampler Phone No.: 716-761-4807

Number: TO BE COMPLETED BY MICROBAC  
 Instructions on back  
 Temperature Upon Receipt (°C): 16.40  
 Therm ID: 7442  
 Holding Time: 16.40  
 Samples Received on Ice? Yes No (N/A)  
 Custody Seals Intact? Yes No (N/A)  
 [X] Results Only [ ] Level 1 [ ] Level 2 [ ] Level 3 [ ] Level 4 [ ] EDD  
 [X] Mail [ ] Fax [ ] e-mail (address)  
 Compliance Monitoring? [X] Yes [ ] No  
 ( ) Agency/Program

\* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)  
 \*\* Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved  
 REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types	Lead	Additional Notes
3-22		2/11/2023	7:44	1	DW	G	None	X	
3-23		2/11/2023	7:44	1	DW	G	None	X	
3-24		2/11/2023	7:45	1	DW	G	None	X	
3-28		2/11/2023	7:46	1	DW	G	None	X	
3-29		2/11/2023	7:47	1	DW	G	None	X	
3-33		2/11/2023	7:52	1	DW	G	None	X	
3-34		2/11/2023	7:52	1	DW	G	None	X	
3-35		2/11/2023	7:53	1	DW	G	None	X	
3-36		2/11/2023	7:54	1	DW	G	None	X	
3-37		2/11/2023	7:54	1	DW	G	None	X	

Possible Hazard Identification: [ ] Hazardous [ ] Non-Hazardous [ ] Radioactive [ ] Disposition as appropriate [X] Return [ ] Archive  
 Comments: 18.4°C TBs, CIL Matrix 2/13  
 Relinquished By (signature): [Signature] Date/Time: 2-13-23 9:40  
 Relinquished By (signature): [Signature] Date/Time: 2-13-23 11:00  
 Relinquished By (signature): [Signature] Date/Time: 2-13-23 13:15  
 Received By (signature): [Signature] Date/Time: 2-13-23 9:40  
 Received By (signature): [Signature] Date/Time: 2-13-23 11:00  
 Received By (signature): [Signature] Date/Time: 2-13-23 13:25



MICROBAC 1962 Wager Rd., Erie, PA 16509 | 814.325.8531

3 0 2 2 1 6 6

CHAIN OF CUSTODY RECORD

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C) 74.42

Holding Time 1640

Samples Received on Ice? Yes No (N/A)

Custody Seals Intact? Yes No (N/A)



Sherman Central School

PM: Carolyn Volentine

Sherman Central School

P.O. Box 950

Sherman, NY 14781

Jared Oehlbeck

716-761-4807

Send Invoice via:

PO No.:

Sherman CSD

Location:

Lead Samples

Project:

Sampled by (PRINT): Jared Oehlbeck

Sampler Signature:

Sampler Phone No.: 716-761-4807

\* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)
\*\* Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

REQUESTED ANALYSIS

Table with columns: Lab ID, Client Sample ID, Date Collected, Time Collected, No. of Containers, Matrix, Grab / Comp, # Preservative Types, Lead, Sample Disposition, Received By (signature), Date/Time

Possible Hazard Identification: 18.4°C TB3, Cu Mat ice 2/13
Comments: 18.4°C TB3, Cu Mat ice 2/13
Received By (signature) and Date/Time for multiple samples.



MICROBAC 1962 Wager Rd., Erie, PA 16509 | 814.82

3 0 2 2 1 6 6

CHAIN OF CUSTODY RECORD

Number Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C) 74.2

Therm ID 1640

Holding Time 16.40

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

[X] Results Only [ ] Level 1 [ ] Level 2 [ ] Level 3 [ ] Level 4 [ ] EDD

[X] Mail [ ] Fax [ ] e-mail (address)

Compliance Monitoring? [X] Yes [ ] No

( ) Agency/Program

Sampler Phone No.: 716-761-4807

Send Invoice via: [X] Mail [ ] Fax [ ] e-mail (address)

PO No.: Sherman CSD

Location: Sherman CSD

Address: 127 Park St

City, State, Zip: Sherman, NY 14781

Contact: Jared Oehlbeck

Telephone No.: 716-761-4807

Client Name: Sherman Central School

Client Address: 1962 Wager Rd., Erie, PA 16509

Client Phone: 814.82

Client Email: [ ] [ ]

Client Fax: [ ] [ ]

Client Zip: 14781

Client City: Sherman

Client State: NY

Client Zip: 14781

Client Contact: Jared Oehlbeck

Client Telephone: 716-761-4807

Client Address: 127 Park St

Client City: Sherman

Client State: NY

Lab Report Address

Client Name: Sherman Central School

Address: 127 Park St

City, State, Zip: Sherman, NY 14781

Contact: Jared Oehlbeck

Telephone No.: 716-761-4807

Send Report via: [X] Mail [ ] Fax [ ] e-mail (address)

Project: Lead Samples

Location: Sherman CSD

Address: 127 Park St

City, State, Zip: Sherman, NY 14781

Contact: Jared Oehlbeck

Telephone No.: 716-761-4807

Client Name: Sherman Central School

Client Address: 1962 Wager Rd., Erie, PA 16509

Client Phone: 814.82

Client Email: [ ] [ ]

Client Fax: [ ] [ ]

Client Zip: 14781

Client City: Sherman

Client State: NY

Client Zip: 14781

Client Contact: Jared Oehlbeck

Client Telephone: 716-761-4807

Client Address: 127 Park St

Client City: Sherman

Client State: NY

Client Zip: 14781

Client Contact: Jared Oehlbeck

Client Telephone: 716-761-4807

Lab ID

Client Sample ID

Date Collected

Time Collected

Date Collected

Time Collected

Date Collected

Time Collected

Date Collected

Time Collected

Date Collected

Time Collected

Date Collected

Time Collected

Date Collected

Time Collected

Date Collected

Time Collected

Date Collected

Time Collected

Date Collected

Time Collected

Date Collected

Time Collected

Date Collected

Time Collected

Date Collected

Time Collected

Date Collected

Time Collected

Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	# Preservative Types	Lead	Additional Notes
5-2		2/11/2023	8:06	1	DW	G	None	X	
5-10		2/11/2023	8:06	1	DW	G	None	X	
5-11		2/11/2023	8:06	1	DW	G	None	X	
5-12		2/11/2023	8:07	1	DW	G	None	X	
5-13		2/11/2023	8:07	1	DW	G	None	X	
5-14		2/11/2023	8:07	1	DW	G	None	X	
5-15		2/11/2023	8:08	1	DW	G	None	X	
5-16		2/11/2023	8:09	1	DW	G	None	X	
5-17		2/11/2023	8:09	1	DW	G	None	X	
6-4		2/11/2023	8:11	1	DW	G	None	X	

184C Tray  
CIC Office 2/13

Relinquished By (signature) [Signature]

Date/Time 2-13-23 9:40

Received By (signature) [Signature]

Date/Time 2-13-23 9:40

Relinquished By (signature) [Signature]

Date/Time 2-13-23 1:00

Received By (signature) [Signature]

Date/Time 2-13-23-1100

Relinquished By (signature) [Signature]

Date/Time 2-13-23 13:15

Received By (signature) [Signature]

Date/Time 2-13-23 15:25

Relinquished By (signature) [Signature]

Date/Time 2-13-23 15:25





CHAIN OF CUSTODY RECORD

MICROBAC 1962 Wager Rd., Erie, PA 16509 | 814 321

Lab Report Address: Sherman Central School, PM: Carolyn Vollenbre

Client Name: Sherman Central School, Address: 127 Park St, Sherman, NY 14781

Contact: Jared Oehlbeck, Telephone No.: 716-761-4807

Send Report via: [X] Mail [ ] Fax [ ] e-mail (address)

Project: Lead Samples, Location: Sherman CSD, PO No.:

Sampled by (PRINT): Jared Oehlbeck, Signature:

\* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

\*\* Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

Requested Analysis: REQUESTED ANALYSIS

Table with columns: Lab ID, Client Sample ID, Date Collected, Time Collected, No. of Containers, Matrix, Grab / Comp, # Preservative Types, Lead, Sample Disposition, Date/Time, Received By (signature), Date/Time

Possible Hazard Identification: [ ] Hazardous [ ] Non-Hazardous [ ] Radioactive [ ] Dispose as appropriate [ ] Return [ ] Archive

Comments: 18.4C T63, CK Matrix 2/15