



# Sherman Central School

127 Park Street • P.O. Box 950 • Sherman, NY 14781-0950  
phone (716) 761-6121 • fax (716) 761-6119  
[www.sherman.wnyric.org](http://www.sherman.wnyric.org)



October 25, 2016

Dear School Community/Staff/Students:

It is a priority of every school district to maintain a safe and healthy learning environment for its students, and clean water is no exception. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead and restricted the lead content of faucets, pipes, and other plumbing materials. Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers, and lakes. New laws that went into effect in 2014 reduced the amount of lead that plumbing fixtures can contain from 8% to 1%. Brass faucets, fittings and valves – including those advertised as “lead free” – may still contribute lead to drinking water.

The Sherman Central School District is in compliance with New York State Public Health Laws requiring all schools and Boards of Cooperative Educational Services (BOCES) to test potable water outlets for lead contamination, to remediate contamination where found, and to notify parents of children and the public of test results. Levels of lead at any water outlet above 15 parts per billion (ppb) require action to remediate this issue.

As required, the Sherman Central School District tested all water sources in every building for lead on September 24, 2016. As provided to us under specific protocols, first draw water samples were taken after letting the water remain unmoving in the pipes over a period of 8 to 18 hours. The results of this testing were received on October 24, 2016 and of the 151 water samples tested, only 7 showed lead levels above the 15 ppb mark.

Listed below are the areas that exceeded the threshold of 15 ppb:

- GR-1 Hose Bib, Maintenance Room, 147 ppb (Not required to be tested, but tested anyway)
- K-1, Kitchen Hand Wash Sink, 72.1 ppb
- K-3, Dishwasher Room, Hand Wash Sink, 23.2 ppb
- K-10, Kitchen Dishwashing Sink, 28.6 ppb
- 2-5, Superintendent's Office Sink, 17.6 ppb
- 2-6, Faculty Restroom Sink, 22.5 ppb
- 3-20, Men's Restroom Sink near Art Room, 15.3 ppb

While we will be taking measures to resolve these sources, we are pleased to report that student drinking fountains and areas where water is used in food preparation are all at acceptable levels. The Sherman Central District is taking a number of steps to correct the problem. We have shut off the water supply to those fixtures used for drinking or cooking. Any water sources used for other purposes such as showering and general cleaning have been clearly labeled with warning signs not to be used for drinking or cooking. The next step is to develop a remediation plan that will be approved and guided by the experts in the field of water remediation.

The timetable for remediation of each of the identified sources will depend on the availability of parts, installation, and the process for retesting. It is important to note that none of the sources will be put back into service and available for drinking or cooking until the sources are fully mitigated and meet New York State Department of Health Standards.

A copy of our water testing results is available at the district office, which is open Monday through Friday from 8:00 am to 4:00 pm. Results are also posted on the District website at [www.sherman.wnyric.org](http://www.sherman.wnyric.org).

For more information about water quality and sampling for lead contact the Erie County Department of Health at 961-6800 or the Chautauqua County Department of Health and Human Services at 753-4000.

Sincerely,

Michael V. Ginestre -- Superintendent

Mr. Michael V. Ginestre • Superintendent  
Mrs. Bryna Booth • Principal  
Mr. Jamie Berg • CSE Chair/Instructional Support Specialist

Board of Education  
Mr. Brian Bates • President  
Mr. Gary DeLellis • Vice President  
Ms. Jennifer Ferreira  
Mrs. Colleen Meeder  
Mrs. Emily Reynolds

Mrs. Kimberly Oehlbeck • School Business Administrator  
Mrs. Tracie D. Smith • District Clerk



Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

16I2378

Sherman Central School District

Project Name: Sherman Central Lead Samples

Jared Oehlbeck  
127 Park Street  
Sherman, NY 14781

Project / PO Number: N/A  
Received: 09/26/2016  
Reported: 10/24/2016

Analytical Testing Parameters

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | Gr-1           | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 8:30           |
| Lab Sample ID:    | 16I2378-01     |                  |                           |

| Metals, Total       | Result | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|--------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |        |            |         |       |      |               |               |
| Lead                | 0.147  | 0.0150 MCL | 0.00100 | mg/L  | X    | 10/07/16 1238 | 10/10/16 1620 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | Gr-2           | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 8:31           |
| Lab Sample ID:    | 16I2378-02     |                  |                           |

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00102 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/04/16 1212 | 10/04/16 2007 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | Gr-3           | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 8:32           |
| Lab Sample ID:    | 16I2378-03     |                  |                           |

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/04/16 1212 | 10/04/16 2007 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | Gr-4           | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 8:36           |
| Lab Sample ID:    | 16I2378-04     |                  |                           |

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00179 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/04/16 1212 | 10/04/16 2007 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | Gr-5           | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 8:34           |
| Lab Sample ID:    | 16I2378-05     |                  |                           |

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00228 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/04/16 1212 | 10/04/16 2007 |

Microbac Laboratories, Inc.

QC473 V1





Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

16I2378

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | Gr-6           | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 8:35           |
| Lab Sample ID:    | 16I2378-06     |                  |                           |

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00708 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/04/16 1212 | 10/04/16 2007 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | Gr-7           | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 8:26           |
| Lab Sample ID:    | 16I2378-07     |                  |                           |

| Metals, Total       | Result | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|--------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |        |            |         |       |      |               |               |
| Lead                | 0.0125 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/04/16 1212 | 10/04/16 2007 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | Gr-8           | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 8:24           |
| Lab Sample ID:    | 16I2378-08     |                  |                           |

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/04/16 1212 | 10/04/16 2007 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | Gr-9           | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 8:23           |
| Lab Sample ID:    | 16I2378-09     |                  |                           |

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00129 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/04/16 1212 | 10/04/16 2007 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | Gr-10          | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 8:23           |
| Lab Sample ID:    | 16I2378-10     |                  |                           |

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00104 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/04/16 1212 | 10/04/16 2007 |



Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

16I2378

Client Sample ID: Gr-11  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-11

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 8:25

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/04/16 1212 | 10/04/16 2007 |

Client Sample ID: Gr-12  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-12

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 8:20

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00468 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/04/16 1212 | 10/04/16 2007 |

Client Sample ID: Gr-13  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-13

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 8:13

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/04/16 1212 | 10/04/16 2007 |

Client Sample ID: Gr-14  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-14

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 8:15

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/04/16 1212 | 10/04/16 2007 |

Client Sample ID: Gr-15  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-15

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 8:16

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00123 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/04/16 1212 | 10/04/16 2007 |





Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

16I2378

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | Gr-16          | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 8:16           |
| Lab Sample ID:    | 16I2378-16     |                  |                           |

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00313 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/04/16 1212 | 10/04/16 2007 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | Gr-17          | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 8:17           |
| Lab Sample ID:    | 16I2378-17     |                  |                           |

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00227 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/04/16 1212 | 10/04/16 2007 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | Gr-18          | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 8:18           |
| Lab Sample ID:    | 16I2378-18     |                  |                           |

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00212 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/04/16 1212 | 10/04/16 2007 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | Gr-19          | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 8:19           |
| Lab Sample ID:    | 16I2378-19     |                  |                           |

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00234 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/04/16 1212 | 10/04/16 2007 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | K-1            | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 8:40           |
| Lab Sample ID:    | 16I2378-21     |                  |                           |

| Metals, Total       | Result | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|--------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |        |            |         |       |      |               |               |
| Lead                | 0.0721 | 0.0150 MCL | 0.00100 | mg/L  | X    | 10/10/16 1623 | 10/10/16 1825 |



Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

16I2378

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | K-2            | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 8:41           |
| Lab Sample ID:    | 16I2378-22     |                  |                           |

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00831 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/10/16 1623 | 10/10/16 1825 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | K-3            | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 8:41           |
| Lab Sample ID:    | 16I2378-23     |                  |                           |

| Metals, Total       | Result | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|--------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |        |            |         |       |      |               |               |
| Lead                | 0.0232 | 0.0150 MCL | 0.00100 | mg/L  | X    | 10/10/16 1623 | 10/10/16 1825 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | K-4            | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 8:43           |
| Lab Sample ID:    | 16I2378-24     |                  |                           |

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00279 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/10/16 1623 | 10/10/16 1825 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | K-5            | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 8:43           |
| Lab Sample ID:    | 16I2378-25     |                  |                           |

| Metals, Total       | Result | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|--------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |        |            |         |       |      |               |               |
| Lead                | 0.0104 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/19/16 1528 | 10/19/16 2006 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | K-6            | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 8:45           |
| Lab Sample ID:    | 16I2378-26     |                  |                           |

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00149 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/10/16 1623 | 10/10/16 1825 |





Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

16I2378

Client Sample ID: K-7  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-27

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 8:48

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00988 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/10/16 1623 | 10/10/16 1825 |

Client Sample ID: K-8  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-28

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 8:49

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00349 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/10/16 1623 | 10/10/16 1825 |

Client Sample ID: K-9  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-29

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 8:49

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00708 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/10/16 1623 | 10/10/16 1825 |

Client Sample ID: K-10  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-30

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 8:49

| Metals, Total       | Result | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|--------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |        |            |         |       |      |               |               |
| Lead                | 0.0286 | 0.0150 MCL | 0.00100 | mg/L  | X    | 10/10/16 1623 | 10/10/16 1825 |

Client Sample ID: K-11  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-31

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 8:47

| Metals, Total       | Result | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|--------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |        |            |         |       |      |               |               |
| Lead                | 0.0143 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/19/16 1528 | 10/19/16 2006 |



Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

16I2378

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | 2-1            | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 8:54           |
| Lab Sample ID:    | 16I2378-32     |                  |                           |

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/19/16 1528 | 10/19/16 2006 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | 2-2            | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 8:54           |
| Lab Sample ID:    | 16I2378-33     |                  |                           |

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/19/16 1528 | 10/19/16 2006 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | 2-3            | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 8:55           |
| Lab Sample ID:    | 16I2378-34     |                  |                           |

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00148 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/19/16 1528 | 10/19/16 2006 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | 2-4            | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 8:57           |
| Lab Sample ID:    | 16I2378-35     |                  |                           |

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/19/16 1528 | 10/19/16 2006 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | 2-5            | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 8:58           |
| Lab Sample ID:    | 16I2378-36     |                  |                           |

| Metals, Total       | Result | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|--------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |        |            |         |       |      |               |               |
| Lead                | 0.0176 | 0.0150 MCL | 0.00100 | mg/L  | X    | 10/19/16 1528 | 10/19/16 2006 |





Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

16I2378

Client Sample ID: 2-6  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-37

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 8:58

| Metals, Total       | Result | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|--------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |        |            |         |       |      |               |               |
| Lead                | 0.0225 | 0.0150 MCL | 0.00100 | mg/L  | X    | 10/19/16 1528 | 10/19/16 2006 |

Client Sample ID: 2-7  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-38

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:02

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00185 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/19/16 1528 | 10/19/16 2006 |

Client Sample ID: 2-8  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-39

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:02

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00131 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/19/16 1528 | 10/19/16 2006 |

Client Sample ID: 3-1  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-40

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:04

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/19/16 1528 | 10/19/16 2006 |

Client Sample ID: 3-2  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-41

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:04

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/19/16 1528 | 10/19/16 2006 |



Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

16I2378

Client Sample ID: 3-3  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-42

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:05

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/19/16 1528 | 10/19/16 2006 |

Client Sample ID: 3-6  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-45

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:06

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/19/16 1528 | 10/19/16 2006 |

Client Sample ID: 3-7  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-46

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:06

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/19/16 1528 | 10/19/16 2006 |

Client Sample ID: 3-8  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-47

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:07

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/19/16 1528 | 10/19/16 2006 |

Client Sample ID: 3-9  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-48

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:09

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00247 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/19/16 1528 | 10/19/16 2006 |





Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

16I2378

Client Sample ID: 3-10  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-49

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:08

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/19/16 1610 | 10/19/16 2123 |

Client Sample ID: 3-11  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-50

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:11

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00284 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/19/16 1610 | 10/19/16 2123 |

Client Sample ID: 3-12  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-51

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:11

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00138 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/19/16 1610 | 10/19/16 2123 |

Client Sample ID: 3-13  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-52

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:12

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00818 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/19/16 1610 | 10/19/16 2123 |

Client Sample ID: 3-14  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-53

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:12

| Metals, Total       | Result | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|--------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |        |            |         |       |      |               |               |
| Lead                | 0.0108 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/19/16 1610 | 10/20/16 1040 |



Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

16I2378

Client Sample ID: 3-15  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-54

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:12

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00704 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/19/16 1610 | 10/19/16 2123 |

Client Sample ID: 3-16  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-55

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:15

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00241 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/19/16 1610 | 10/19/16 2123 |

Client Sample ID: 3-17  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-56

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:15

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00372 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/19/16 1610 | 10/19/16 2123 |

Client Sample ID: 3-18  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-57

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:15

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00664 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/19/16 1610 | 10/19/16 2123 |

Client Sample ID: 3-19  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-58

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:20

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00599 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/19/16 1610 | 10/19/16 2123 |





Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

16I2378

Client Sample ID: 3-20  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-59

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:20

| Metals, Total       | Result | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|--------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |        |            |         |       |      |               |               |
| Lead                | 0.0153 | 0.0150 MCL | 0.00100 | mg/L  | X    | 10/19/16 1610 | 10/20/16 1040 |

Client Sample ID: 3-21  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-60

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:20

| Metals, Total       | Result | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|--------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |        |            |         |       |      |               |               |
| Lead                | 0.0124 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/19/16 1610 | 10/20/16 1040 |

Client Sample ID: 3-22  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-61

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:17

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00186 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/19/16 1610 | 10/20/16 1040 |

Client Sample ID: 3-23  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-62

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:17

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00219 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/19/16 1610 | 10/20/16 1040 |

Client Sample ID: 3-24  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-63

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:17

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00255 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/19/16 1610 | 10/20/16 1040 |



Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

16I2378

Client Sample ID: 3-25  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-64

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:26

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00240 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/19/16 1610 | 10/20/16 1040 |

Client Sample ID: 3-26  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-65

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:25

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00121 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/19/16 1610 | 10/20/16 1040 |

Client Sample ID: 3-27  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-66

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:27

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00331 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/19/16 1610 | 10/20/16 1040 |

Client Sample ID: 3-28  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-67

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 7:59

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/19/16 1610 | 10/20/16 1040 |

Client Sample ID: 3-29  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-68

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 7:59

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/19/16 1610 | 10/20/16 1040 |



Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

16I2378

Client Sample ID: 3-30  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-69

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:25

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00392 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1037 | 10/20/16 1240 |

Client Sample ID: 3-31  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-70

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:25

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00864 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1037 | 10/20/16 1240 |

Client Sample ID: 3-32  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-71

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:25

| Metals, Total       | Result | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|--------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |        |            |         |       |      |               |               |
| Lead                | 0.0127 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1037 | 10/20/16 1240 |

Client Sample ID: 3-33  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-72

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:28

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00174 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1037 | 10/20/16 1240 |

Client Sample ID: 3-34  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-73

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:33

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00154 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1037 | 10/20/16 1240 |





Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

16I2378

Client Sample ID: 3-35  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-74

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:35

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00302 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1037 | 10/20/16 1240 |

Client Sample ID: 3-36  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-75

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:34

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00122 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1037 | 10/20/16 1240 |

Client Sample ID: 3-37  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-76

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:34

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1037 | 10/20/16 1240 |

Client Sample ID: 3-38  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-77

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:34

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1037 | 10/20/16 1240 |

Client Sample ID: 3-39  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-78

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:40

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1037 | 10/20/16 1240 |



Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

16I2378

Client Sample ID: 3-40  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-79

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:37

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1037 | 10/20/16 1240 |

Client Sample ID: 3-41  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-80

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:37

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1037 | 10/20/16 1240 |

Client Sample ID: 3-42  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-81

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:39

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1037 | 10/20/16 1240 |

Client Sample ID: 3-43  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-82

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:39

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00145 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1037 | 10/20/16 1240 |

Client Sample ID: 3-44  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-83

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:42

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00223 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1037 | 10/20/16 1240 |



Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

16I2378

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | 3-45           | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 9:41           |
| Lab Sample ID:    | 16I2378-84     |                  |                           |

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1037 | 10/20/16 1240 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | 3-46           | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 9:41           |
| Lab Sample ID:    | 16I2378-85     |                  |                           |

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1037 | 10/20/16 1240 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | 4-1            | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 9:44           |
| Lab Sample ID:    | 16I2378-86     |                  |                           |

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00133 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1037 | 10/20/16 1240 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | 4-2            | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 9:44           |
| Lab Sample ID:    | 16I2378-87     |                  |                           |

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00119 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1037 | 10/20/16 1240 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | 4-3            | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 9:44           |
| Lab Sample ID:    | 16I2378-88     |                  |                           |

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1037 | 10/20/16 1240 |





Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

16I2378

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | 4-4            | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 9:47           |
| Lab Sample ID:    | 16I2378-89     |                  |                           |

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1605 | 10/20/16 1638 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | 4-5            | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 9:45           |
| Lab Sample ID:    | 16I2378-90     |                  |                           |

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00372 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1605 | 10/20/16 1638 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | 4-6            | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 9:45           |
| Lab Sample ID:    | 16I2378-91     |                  |                           |

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1605 | 10/20/16 1638 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | 4-7            | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 10:08          |
| Lab Sample ID:    | 16I2378-92     |                  |                           |

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1605 | 10/20/16 1638 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | 4-8            | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 10:08          |
| Lab Sample ID:    | 16I2378-93     |                  |                           |

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1605 | 10/20/16 1638 |



Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

16I2378

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | 4-9            | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 9:50           |
| Lab Sample ID:    | 16I2378-94     |                  |                           |

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00411 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1605 | 10/20/16 1638 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | 4-10           | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 9:50           |
| Lab Sample ID:    | 16I2378-95     |                  |                           |

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00499 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1605 | 10/20/16 1638 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | 4-11           | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 9:51           |
| Lab Sample ID:    | 16I2378-96     |                  |                           |

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00271 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1605 | 10/20/16 1638 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | 4-12           | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 9:48           |
| Lab Sample ID:    | 16I2378-97     |                  |                           |

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00381 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1605 | 10/20/16 1638 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | 4-13           | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 9:51           |
| Lab Sample ID:    | 16I2378-98     |                  |                           |

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00351 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1605 | 10/20/16 1638 |



Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

16I2378

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | 4-14           | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 9:49           |
| Lab Sample ID:    | 16I2378-99     |                  |                           |

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00665 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1605 | 10/20/16 1638 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | 4-15           | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 9:48           |
| Lab Sample ID:    | 16I2378-AA     |                  |                           |

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00192 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1605 | 10/20/16 1638 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | 4-16           | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 9:51           |
| Lab Sample ID:    | 16I2378-AB     |                  |                           |

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00170 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1605 | 10/20/16 1638 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | 4-17           | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 9:53           |
| Lab Sample ID:    | 16I2378-AC     |                  |                           |

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00155 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1605 | 10/20/16 1638 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | 4-18           | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 9:53           |
| Lab Sample ID:    | 16I2378-AD     |                  |                           |

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00126 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1605 | 10/20/16 1638 |





Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

16I2378

Client Sample ID: 4-19  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-AE

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:54

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00411 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1605 | 10/20/16 1638 |

Client Sample ID: 4-20  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-AF

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:54

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00355 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1605 | 10/20/16 1638 |

Client Sample ID: 4-21  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-AG

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:55

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00245 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1605 | 10/20/16 1638 |

Client Sample ID: 4-22  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-AH

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:56

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00329 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1605 | 10/20/16 1638 |

Client Sample ID: 4-23  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-AI

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:57

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00982 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1605 | 10/20/16 1638 |



Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

16I2378

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | 4-24           | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 9:58           |
| Lab Sample ID:    | 16I2378-AJ     |                  |                           |

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00310 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1712 | 10/20/16 1904 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | 4-25           | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 9:58           |
| Lab Sample ID:    | 16I2378-AK     |                  |                           |

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00410 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1712 | 10/20/16 1904 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | 4-26           | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 9:59           |
| Lab Sample ID:    | 16I2378-AL     |                  |                           |

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00334 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1712 | 10/20/16 1904 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | 4-27           | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 9:59           |
| Lab Sample ID:    | 16I2378-AM     |                  |                           |

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00380 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1712 | 10/20/16 1904 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | 4-28           | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 10:00          |
| Lab Sample ID:    | 16I2378-AN     |                  |                           |

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00439 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1712 | 10/20/16 1904 |



Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

16I2378

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | 4-29           | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 10:02          |
| Lab Sample ID:    | 16I2378-AO     |                  |                           |

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00847 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1712 | 10/20/16 1904 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | 4-30           | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 10:01          |
| Lab Sample ID:    | 16I2378-AP     |                  |                           |

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00736 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1712 | 10/20/16 1904 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | 4-31           | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 10:01          |
| Lab Sample ID:    | 16I2378-AQ     |                  |                           |

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00464 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1712 | 10/20/16 1904 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | 4-32           | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 10:03          |
| Lab Sample ID:    | 16I2378-AR     |                  |                           |

| Metals, Total       | Result | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|--------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |        |            |         |       |      |               |               |
| Lead                | 0.0113 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1712 | 10/20/16 1904 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | 5-1            | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 10:11          |
| Lab Sample ID:    | 16I2378-AS     |                  |                           |

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1712 | 10/20/16 1904 |





Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

16I2378

Client Sample ID: 5-2  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-AT

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 10:11

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1712 | 10/20/16 1904 |

Client Sample ID: 5-3  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-AU

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 10:12

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00190 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1712 | 10/20/16 1904 |

Client Sample ID: 5-4  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-AV

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 10:13

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1712 | 10/20/16 1904 |

Client Sample ID: 5-5  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-AW

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 10:13

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1712 | 10/20/16 1904 |

Client Sample ID: 5-6  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-AX

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 10:13

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1712 | 10/20/16 1904 |



Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

16I2378

Client Sample ID: 5-7  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-AY

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 10:15

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1712 | 10/20/16 1904 |

Client Sample ID: 5-8  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-AZ

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 10:15

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1712 | 10/20/16 1904 |

Client Sample ID: 5-9  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-BA

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 10:15

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1712 | 10/20/16 1904 |

Client Sample ID: 5-10  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-BB

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 10:18

| Metals, Total       | Result | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|--------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |        |            |         |       |      |               |               |
| Lead                | 0.0110 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1712 | 10/20/16 1904 |

Client Sample ID: 5-11  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-BC

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 10:19

| Metals, Total       | Result | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|--------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |        |            |         |       |      |               |               |
| Lead                | 0.0118 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1712 | 10/20/16 1904 |



Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

16I2378

Client Sample ID: 5-12  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-BD

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 10:30

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1754 | 10/21/16 1339 |

Client Sample ID: 5-13  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-BE

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 10:31

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1754 | 10/21/16 1339 |

Client Sample ID: 5-14  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-BF

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 10:21

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1754 | 10/21/16 1339 |

Client Sample ID: 5-15  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-BG

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 10:21

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1754 | 10/21/16 1339 |

Client Sample ID: 5-16  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-BH

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 10:32

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00284 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1754 | 10/21/16 1339 |





Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

16I2378

Client Sample ID: 5-17  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-BI

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 10:33

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00787 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1754 | 10/21/16 1339 |

Client Sample ID: 6-1  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-BJ

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 10:36

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1754 | 10/21/16 1339 |

Client Sample ID: 6-2  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-BK

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 10:36

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00101 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1754 | 10/21/16 1339 |

Client Sample ID: 6-3  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-BL

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 10:36

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00130 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1754 | 10/21/16 1339 |

Client Sample ID: 6-4  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-BM

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 10:38

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1754 | 10/21/16 1339 |



Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

16I2378

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | 6-5            | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 10:38          |
| Lab Sample ID:    | 16I2378-BN     |                  |                           |

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1754 | 10/21/16 1339 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | 6-6            | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 10:40          |
| Lab Sample ID:    | 16I2378-BO     |                  |                           |

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1754 | 10/21/16 1339 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | 6-7            | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 10:40          |
| Lab Sample ID:    | 16I2378-BP     |                  |                           |

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1754 | 10/21/16 1339 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | AF-1           | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 10:48          |
| Lab Sample ID:    | 16I2378-BQ     |                  |                           |

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1754 | 10/21/16 1339 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | AF-2           | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 10:48          |
| Lab Sample ID:    | 16I2378-BR     |                  |                           |

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1754 | 10/21/16 1339 |



Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

16I2378

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | AF-3           | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 10:51          |
| Lab Sample ID:    | 16I2378-BS     |                  |                           |

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1754 | 10/21/16 1339 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | AF-4           | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 10:52          |
| Lab Sample ID:    | 16I2378-BT     |                  |                           |

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1754 | 10/21/16 1339 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | B-1            | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 10:56          |
| Lab Sample ID:    | 16I2378-BU     |                  |                           |

| Metals, Total       | Result   | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|----------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |          |            |         |       |      |               |               |
| Lead                | <0.00100 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/20/16 1754 | 10/21/16 1339 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | B-2            | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 10:57          |
| Lab Sample ID:    | 16I2378-BV     |                  |                           |

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00637 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/21/16 1326 | 10/21/16 1515 |

|                   |                |                  |                           |
|-------------------|----------------|------------------|---------------------------|
| Client Sample ID: | B-3            | Collected By:    | Doug Crane/Jared Oehlbeck |
| Sample Matrix:    | Drinking Water | Collection Date: | 09/24/2016 10:57          |
| Lab Sample ID:    | 16I2378-BW     |                  |                           |

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00683 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/21/16 1326 | 10/21/16 1515 |





Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

16I2378

Client Sample ID: B-4  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-BX

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 10:58

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00525 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/21/16 1326 | 10/21/16 1515 |

Client Sample ID: B-5  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-BY

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 10:56

| Metals, Total       | Result | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|--------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |        |            |         |       |      |               |               |
| Lead                | 0.0111 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/21/16 1326 | 10/21/16 1515 |

Client Sample ID: 4-33  
Sample Matrix: Drinking Water  
Lab Sample ID: 16I2378-BZ

Collected By: Doug Crane/Jared Oehlbeck  
Collection Date: 09/24/2016 9:56

| Metals, Total       | Result  | Limit(s)   | RL      | Units | Note | Prepared      | Analyzed      |
|---------------------|---------|------------|---------|-------|------|---------------|---------------|
| Method: SM3113 B-04 |         |            |         |       |      |               |               |
| Lead                | 0.00350 | 0.0150 MCL | 0.00100 | mg/L  |      | 10/21/16 1326 | 10/21/16 1515 |

Definitions

MCL: Maximum Contaminant Level  
RL: Reporting Limit  
X: Exceeds regulatory limit.

Project Requested Certification(s)

Microbac Laboratories, Inc. - Erie  
NY DOH# 10121

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

Limits may be provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Reviewed and Approved By:

Carolyn V. Vollenentine

Carolyn Vollenentine  
Project Manager  
carolyn.vollenentine@microbac.com  
10/24/2016 08:58